

WELL CONSTRUCTOR'S REPORT

Well-6.

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPYSTATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

| | | | | | |
|--|----------------------|--|------------------|--------------------------|---------------------|
| 1. COUNTY Ozaukee | | CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City | | NAME Cedarburg | |
| 2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available) NW 1/4 OF SE 1/4 OF SEC. 26 T 10 NR 21 E | | | | | |
| 3. OWNER AT TIME OF DRILLING Royal Edmark | | | | | |
| 4. OWNER'S COMPLETE MAIL ADDRESS Edgewater Drive Grafton, Wis. | | | | | |
| 5. Distance in feet from well to nearest: (Record answer in appropriate block) | | BUILDING C. I. | SANITARY TILE | SEWER C. I. | FLOOR DRAIN TILE |
| 14 | | | | | |
| | | FOUNDATION DRAIN SEWER CONNECTED | | INDEPENDENT | |
| | | 14 | | | |
| CLEAR WATER DRAIN C. I. | SEPTIC TANK TILE | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN |
| | not installed | | | | |
| OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) | | | | | |
| 6. Well is intended to supply water for: House | | | | | |

| 7. DRILLHOLE | | | | | | 10. FORMATIONS | | |
|--|----------------------------|-----------|----------------|------------|------------|--|----------------|------------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| 60 | Surface | 40 | 6 | 40 | 174 | Sandy Clay | Surface | 69 |
| | | | | | | Hardpan | 69 | 84 |
| 8. CASING, LINER, CURBING, AND SCREEN | | | | | | | | |
| Dia. (in.) | Kind and Weight | | From (ft.) | To (ft.) | | | | |
| 6 | 19.45# new bl steel | | Surface | 84 | | Limestone | 84 | 174 |
| | T&C well cas. | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 9. GROUT OR OTHER SEALING MATERIAL | | | | | | | | |
| Kind | | | From (ft.) | To (ft.) | | | | |
| clay slurry | | | Surface | 40 | | | | |
| | | | | | | Well construction completed on 7/27/71 19 | | |
| 11. MISCELLANEOUS DATA | | | | | | | | |
| Yield test: | | 10 | Hrs. at | 15 | GPM | Well is terminated 10 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade | | |
| Depth from surface to normal water level | | 48 | ft. | | | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| Depth to water level when pumping | | 58 | ft. | | | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| Water sample sent to | | | | | | laboratory on: 7/27/71 19 | | |

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

| | | | |
|------------------------------------|--|--|--|
| SIGNATURE <i>Robert Deneath</i> | | COMPLETE MAIL ADDRESS 631 South Wash. Ave. Cedarburg, Wis. | |
| Registered Well Driller | | | |

Please do not write in space below

| | | | | | | | |
|---------------|--|---------------|--|-----------|--|---------|--|
| GAS - 24 HRS. | | GAS - 48 HRS. | | CONFIRMED | | REMARKS | |
| | | | | | | | |